

RESOLUTION #2021 – 29

**RESOLUTION OF THE MANTUA TOWNSHIP
MUNICIPAL UTILITIES AUTHORITY
AUTHORIZING EMERGENCY REPLACEMENT OF THE PUMP AND COLUMN
ASSEMBLY TO WELL #8**

WHEREAS, the Mantua Township Municipal Utilities Authority (“MTMUA”), has its principal place of business at 397 Main Street, Mantua, New Jersey 08051; and

WHEREAS, the purpose of the MTMUA is the provisioning of water and sewer services to the residents of Mantua Township; and

WHEREAS, A.C. Schultes conducted an inspection of Well #8 detailed in a report dated March 18, 2021, and incorporated herein at length, opining that the Well #8 pump and column assembly is breaking and should be removed and replaced with new parts; and


WHEREAS, the MTMUA residents rely on Well #8, among others, for potable water, and public bidding for the necessary repairs could take months to complete and loss of Well #8 would have an immediate and significant impact on the MTMUA’s ability to provision water.

NOW, THEREFORE, BE IT RESOLVED, by the Mantua Township Municipal Utilities Authority as follows:

1. Emergency replacement of pump and column assembly for Well #8 is hereby authorized without competitive bidding repairs.
2. A test pump will be installed after redevelopment to ascertain the current condition of the well as outlined in A.C. Shultes TV Report dated March 18, 2021 and incorporated herein at length.

DULY ADOPTED at the Regular Meeting of the Mantua Township Municipal Utilities Authority held on April 20, 2021.

**The Mantua Township
Municipal Utilities Authority**

By: 

Timothy Sheehan, Chairman

ATTEST:



John Parks, Secretary

<u>Governing Body</u>	<u>Recorded Vote</u>		<u>Resolution 2021-29</u>	
	<u>Aye</u>	<u>Nay</u>	<u>Abstain</u>	<u>Absent</u>
Tim Sheehan, Chairman	✓			
Mario Dilisciandro, Vice Chairman	✓			
Daniel Hauss, Treasurer	✓			
John Parks, Secretary	✓			
Victor Torino	✓			
Howard Bruner, Alternate No. 1				✓